CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7300-0992:0144 Page 1 of 2

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Napco333 Bayview Avene, Amityville, NY 11701

Contact: David Wagner (631) 842-9400 Fax (631) 842-2726

Email: dwagner@napcosecurity.com

DESIGN: Models SLE3/4G-CB, SLE3/4G-CB-TF, SLE3/4G-CFB, SLE3/4G-CFB-PS, SLE-CDMA,

SLE-CDMA-FIRE, SLE-GSM-3/4G, SLE-GSM-FIRE, SLECDMA-CB, SLECDMA-CB-TF, SLECDMA-CFB, SLECDMA-CFB-PS, SLE-LTEV-FIRE, SLE-LTEV-8D, SLE-LTEV, SLE-LTEV-CFB-PS, SLE-LTEV-CB-TF, SLE-LTEV-CFB, SLE-LTEV-CB, SLE-LTEA-CFB, SLE-LTEA-CFB-PS and SLE-LTEA-FIRE Sole Path Communicators. Model numbers may

be followed by an alpha/numeric suffix for marketing purposes.

Models SLECDMAI-CFB-PS, SLE3/4GI-CFB-PS, SLECDMAI-CB-TF, SLE3/4GI-CB-TF, SLECDMAI-CFB, SLE3/4GI-CFB, SLECDMAI-CB, SLE3/4GI-CB, SLE-GSMI-3/4G, SLE-CDMAI, SLE-GSMI-FIRE, SLE-CDMAI-FIRE, SLE-LTEVI-CFBPS, SLE-LTEVI-CFB, SLE-LTEVI-FIRE, *SLE-LTEAI-CFBPS, *SLE-LTEAI-CFB and *SLE-LTEAI-FIRE. Dual Path Communicators. Model numbers may be followed by an alpha/numeric suffix for marketing purposes.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 Vac - SLE3/4G-CB, SLE3/4GI-CB-TF, SLE3/4G-CFB-PS, SLE3/4GI-CFB-PS,

SLECDMA-CFB-PS, SLECDMAI-CFB-PS, SLECDMA-CB-TF, SLECDMAI-CB-TF, SLE-LTEV-CFB-PS, SLE-LTEV-C

*SLE-LTEAI-CFBPS

10-15 Vdc- SLECDMAI-CB, SLE3/4GI-CB, SLE-GSMI-3/4G, SLE-CDMAI, SLE-LTEV,

SLE-LTEV-8D, SLE-LTEV-CB

10-25 Vdc- SLECDMAI-CFB, SLE3/4GI-CFB, SLE-GSMI-FIRE, SLE-CDMAI-FIRE, SLE-LTEV-FIRE, SLE-LTEV-CFB, SLE-LTEVI-FIRE, SLE-LTEA-CFB, SLE-LTEA-FIRE,

*SLE-LTEAI-FIRE, *SLE-LTEAI-CFB, SLE-LTEVI-CFB

11-15 Vdc- SLE3/4G-CB, SLE-CDMA, SLE-GSM-3/4G, SLECDMA-CB

11-25 Vdc - SLE3/4G-CFB, SLECDMA-CFB, SLE-CDMA-FIRE, SLE-GSM-FIRE

*Rev 09-23-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2019 Listing Expires June 30, 2020

Authorized By: DAVID CASTILLO, M.E., F.P.E., Program Coordinator

Fire Engineering Division

Listing No. 7300-0992:0144

Page 2 of 2

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control

units. Refer to listee's Installation Instruction Manual for details.

*Rev 09-23-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2019 Listing Expires June 30, 2020

Authorized By: DAVID CASTILLO, M.E., F.P.E., Program Coordinator

Fire Engineering Division